



中国认可  
国际互认  
检测  
TESTING  
CNASL0354

# TEST REPORT

Report No.: JKF20022820R1

Zhejiang Academy of Science and Technology for Inspection and Quarantine

Add: No. 398, Jianshe 3 Road, Xiaoshan District, Hangzhou, Zhejiang, China

Tel: +86 0571 8352 7187/185/193 Website: www.zaiq.org.cn





Report No.: JKF20022820R1

Report date: 2020-11-17

The information are provided by client(applicant):				
Sample Information	Sample Name:	Filtering half mask		
	Style No.:	CARE1988V		
	Size:	CARE1988V		
	Brand:	FUXIBIO		
Customer Information	Applicant:			
	Address:			
	Manufacturer:			
	Manufacturer address:			
The information are confirmed by testing organization:				
Test Information	Date of sample received:	2020-10-19	Testing period:	2020-10-19 to 2020-10-27
	Quantity:	60 Pieces		
	Sample description:	White mask		
	Basis of judgment:	EN 149:2001+A1:2009 FFP3 NR Respiratory protective devices—Filtering half masks to protect against particles —Requirements, testing, marking		
Test Conclusion	The items tested meet the requirements of EN 149:2001+A1:2009 FFP3 NR			
Test Result	Please refer to next pages.			
Remark	This report (which has modified Brand, Address and Manufacturer address) is to replace the original report (report number JKF20022820 issued on 2020-10-27), the original report also void.			

Edit:

Ye yiwen

Sign:

Zhao dong

\*\*\* End of this page\*\*\*





Report No.: JKF20022820R1

Report date: 2020-11-17

**Test Results:****Clause 7.5 Material**

(EN 149:2001+A1:2009 Clause 8.2 &amp; 8.3.1 &amp; 8.3.2)

Requirement	Results	Rating
Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used. After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps. When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse. Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Comply	Pass

**Clause 7.6 Cleaning and disinfecting**

(EN 149:2001+A1:2009 Clause 8.4 &amp; 8.5 &amp; 8.11)

Requirement	Results	Rating
If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer. With reference to 7.9.2, after cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.	Not applicable (Not designed to be re-usable)	N/A

**Clause 7.7 Practical performance**

(EN 149:2001+A1:2009 Clause 8.4)

Requirement	Results	Rating
The particle filtering half mask shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the equipment for imperfections that cannot be determined by the tests described elsewhere in this standard.	No imperfections	Pass

**Clause 7.8 Finish of parts**

(EN 149:2001+A1:2009 Clause 8.2)

Requirement	Results	Rating
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	No sharp edges or burrs	Pass



**Clause 7.9.1 Total inward leakage**

(EN 149:2001+A1:2009 Clause 8.5)

Requirement	Results	Rating
For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual exercise results (i.e. 10 subjects x 5 exercises) for total inward leakage shall be not greater than: 25% for FFP1, 11% for FFP2, 5% for FFP3 and, in addition, at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall be not greater than: 22% for FFP1, 8% for FFP2, 2% for FFP3	48 out of the 50 individual exercise $\leq$ 5% 8 out of the 10 individual wearer arithmetic means $\leq$ 2%	Pass

Table 7.9.1-A Inward leakage test data

Subject	Sample No.	Condition	Walk (%)	Head side/side (%)	Head up/down (%)	Talk (%)	Walk (%)	Mean (%)
TLB	1	As received	0.704	0.988	1.025	0.987	1.032	0.947
TY	2		0.975	0.875	0.774	4.321	0.687	1.526
HML	3		0.687	0.875	0.845	1.365	0.987	0.952
LJF	4		1.347	1.443	1.807	6.322	2.176	2.619
CQQ	5		1.035	0.964	1.745	2.155	0.875	1.355
WLJ	6	Temperature conditioned	2.687	2.376	2.187	5.968	3.542	3.352
ZJH	7		1.268	1.347	1.698	2.687	0.897	1.579
RK	8		1.987	1.65	1.457	2.641	1.230	1.790
ZD	9		1.311	1.182	1.689	2.589	0.756	1.505
WG	10		1.369	1.587	1.463	2.645	1.547	1.722

Table 7.9.1-B Facial dimensions

Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)
TLB	125	152	111	57
TY	126	124	95	54
HML	124	130	115	55
LJF	125	135	90	55
CQQ	136	167	125	65
WLJ	132	159	110	60
ZJH	122	150	104	50
RK	112	161	146	50
ZD	116	160	115	55
WG	120	152	109	57





Report No.: JKF20022820R1

Report date: 2020-11-17

**Clause 7.9.2 Penetration of filter material**

(EN 149:2001+A1:2009 Clause 8.11 &amp; EN 13274-7:2019)

Requirement			Results	Rating
The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.			Detail refer to Table 7.9.2	Pass
Classification	Sodium chloride test 95 L/min	Paraffin oil test 95 L/min		
FFP1	≤20%	≤20%		
FFP2	≤6%	≤6%		
FFP3	≤1%	≤1%		

Table 7.9.2 Penetration of filter material

Aerosol	Condition	Sample No.	Penetration (%)
Sodium chloride test	As received	11	0.001
		12	0.001
		13	0.001
	Simulated wearing treatment	14	0.002
		15	0.004
		16	0.004
	Mechanical strength+ Temperature conditioned	17	0.011
		18	0.026
		19	0.017
Paraffin oil test	As received	20	0.001
		21	0.001
		22	0.002
	Simulated wearing treatment	23	0.005
		24	0.006
		25	0.006
	Mechanical strength+ Temperature conditioned	26	0.022
		27	0.031
		28	0.029

Flow conditioning: single filter: 95.0 L/min

**Clause 7.10 Compatibility with skin**

(EN 149:2001+A1:2009 Clause 8.4 &amp; 8.5)

Requirement	Results	Rating
Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.	No irritation or any other adverse effect to health	Pass



**Clause 7.11 Flammability**

(EN 149:2001+A1:2009 Clause 8.6)

Requirement	Results	Rating
When tested, the particle filtering half mask shall not burn or not to continue to burn for more than 5s after removal from the flame.	Detail refer to Table 7.11	Pass

Table 7.11 Flammability

Condition	Sample No.	Result
As received	29	Not burn
	30	Not burn
Temperature conditioned	31	Not burn
	32	Not burn

**Clause 7.12 Carbon dioxide content of the inhalation air**

(EN 149:2001+A1:2009 Clause 8.7)

Requirement	Results	Rating
The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1.0 % (by volume).	Detail refer to Table 7.12	Pass

Table 7.12 Carbon dioxide content of the inhalation air

Condition	Sample No.	Result (%)
As received	33	0.88
	34	0.70
	35	0.84
		Mean value: 0.81

**Clause 7.13 Head harness**

(EN 149:2001+A1:2009 Clause 8.4 & 8.5)

Requirement	Results	Rating
The head harness shall be designed so that the particle filtering half mask can be donned and removed easily. The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and be capable of maintaining total inward leakage requirements for the device.	Comply	Pass

**Clause 7.14 Field of vision**

(EN 149:2001+A1:2009 Clause 8.4)

Requirement	Results	Rating
The field of vision is acceptable if determined so in practical performance tests.	Comply	Pass





Report No.: JKF20022820R1

Report date: 2020-11-17

**Clause 7.15 Exhalation valve**

(EN 149:2001+A1:2009 Clause 8.2 &amp; 8.9.1 &amp; 8.3.4 &amp; 8.8)

Requirement	Results	Rating
<p>A particle filtering half mask may have one or more exhalation valve(s), which shall function correctly in all orientations.</p> <p>If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9.</p> <p>Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 L/min over a period of 30 s.</p> <p>When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 10 N applied for 10 s.</p>	Comply	Pass

**Clause 7.16 Breathing resistance**

(EN 149:2001+A1:2009 Clause 8.9)

Requirement	Results	Rating																						
<p>The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.</p> <table border="1"> <thead> <tr> <th rowspan="3">Classification</th> <th colspan="3">Maximum permitted resistance (mbar)</th> </tr> <tr> <th colspan="2">Inhalation</th> <th>Exhalation</th> </tr> <tr> <th>30L/min</th> <th>95L/min</th> <th>160L/min</th> </tr> </thead> <tbody> <tr> <td>FFP1</td> <td>0.6</td> <td>2.1</td> <td>3.0</td> </tr> <tr> <td>FFP2</td> <td>0.7</td> <td>2.4</td> <td>3.0</td> </tr> <tr> <td>FFP3</td> <td>1.0</td> <td>3.0</td> <td>3.0</td> </tr> </tbody> </table>	Classification	Maximum permitted resistance (mbar)			Inhalation		Exhalation	30L/min	95L/min	160L/min	FFP1	0.6	2.1	3.0	FFP2	0.7	2.4	3.0	FFP3	1.0	3.0	3.0	Detail refer to Table 7.16	Pass
Classification		Maximum permitted resistance (mbar)																						
		Inhalation		Exhalation																				
	30L/min	95L/min	160L/min																					
FFP1	0.6	2.1	3.0																					
FFP2	0.7	2.4	3.0																					
FFP3	1.0	3.0	3.0																					

Table 7.16 Breathing resistance (mbar)

Test item	Condition	Sample No.	A	B	C	D	E
Inhalation (30 L/min)	As received	36	0.75	0.75	0.75	0.75	0.75
		37	0.77	0.77	0.76	0.76	0.77
		38	0.77	0.78	0.78	0.77	0.77
	Simulated wearing treatment	39	0.74	0.75	0.75	0.73	0.74
		40	0.81	0.80	0.80	0.80	0.81
		41	0.74	0.75	0.74	0.74	0.75
	Temperature conditioned	42	0.69	0.69	0.69	0.69	0.69
		43	0.72	0.72	0.72	0.72	0.71
		44	0.69	0.68	0.68	0.69	0.69
	Flow conditioned	45	0.71	0.71	0.70	0.71	0.71
		46	0.75	0.75	0.75	0.74	0.74
		47	0.76	0.76	0.76	0.76	0.76



Test item	Condition	Sample No.	A	B	C	D	E
Inhalation (95 L/min)	As received	36	2.75	2.76	2.77	2.75	2.76
		37	2.82	2.81	2.81	2.82	2.81
		38	2.84	2.85	2.83	2.83	2.84
	Simulated wearing treatment	39	2.92	2.93	2.94	2.93	2.94
		40	2.94	2.96	2.94	2.95	2.96
		41	2.89	2.90	2.92	2.89	2.88
	Temperature conditioned	42	2.42	2.43	2.42	2.42	2.43
		43	2.59	2.59	2.59	2.60	2.60
		44	2.52	2.51	2.51	2.52	2.52
	Flow conditioned	45	2.78	2.76	2.78	2.77	2.77
		46	2.81	2.80	2.79	2.79	2.80
47		2.92	2.94	2.92	2.91	2.92	
Exhalation (160 L/min)	As received	36	1.64	1.65	1.64	1.64	1.65
		37	1.76	1.74	1.77	1.75	1.74
		38	1.69	1.68	1.70	1.69	1.71
	Simulated wearing treatment	39	1.67	1.66	1.68	1.67	1.66
		40	1.76	1.77	1.77	1.76	1.76
		41	1.69	1.68	1.67	1.69	1.68
	Temperature conditioned	42	1.56	1.57	1.57	1.55	1.57
		43	1.65	1.64	1.64	1.65	1.65
		44	1.60	1.61	1.61	1.60	1.60
	Flow conditioned	45	1.59	1.58	1.59	1.59	1.58
		46	1.76	1.73	1.74	1.77	1.75
47		1.77	1.74	1.76	1.75	1.74	

A: facing directly ahead; B: facing vertically upwards; C: facing vertically downwards; D: lying on the left side; E: lying on the right side

**Clause 7.17 Clogging**

(EN 149:2001+A1:2009 Clause 8.9 & 8.10)

Requirement	Results	Rating
<p><b>7.17.2 Breathing resistance:</b></p> <p><b>7.17.2.1 Valved particle filtering half masks</b> After clogging the inhalation resistances shall not exceed FFP1:4mbar, FFP2:5mbar, FFP3:7mbar at 95 L/min continuous flow; The exhalation resistance shall not exceed 3mbar at 160 L/min continuous flow.</p> <p><b>7.17.2.2 Valveless particle filtering half masks</b> After clogging the inhalation and exhalation resistances shall not exceed FFP1:3mbar, FFP2:4mbar, FFP3:5mbar at 95 L/min continuous flow.</p> <p><b>7.17.3 Penetration of filter material:</b> All types (valved and valveless) of particle filtering half masks claimed to meet the clogging requirement shall also meet the requirements given in 7.9.2, for the Penetration test according to EN 13274-7, after the clogging treatment.</p>	<p>Not applicable (Single shift use only)</p>	<p>N/A</p>





Report No.: JKF20022820R1


Report date: 2020-11-17

**Clause 7.18 Demountable parts**

(EN 149:2001+A1:2009 Clause 8.2)

Requirement	Results	Rating
All demountable parts (if fitted) shall be readily connected and secured, where possible by hand.	Comply	Pass

**Sample photo**



\*\*\* End of Report\*\*\*

## STATEMENT

1. Our organization guarantees impartiality, independence and honesty of inspection, and is responsible for the content of report, except for the information provided by the client. The client shall not use the test results for improper publicity without authorization.
2. Our organization shall not be responsible for the authenticity of the information provided by the client, nor shall bear the risks arising in the process of sample delivery. Test result is only responsible for the sample.
3. This report is invalid without the dedicated seal for inspection and testing report and the paging seal.
4. This report is invalid without the signature of the approver (authorized signatory).
5. Test report is invalid if altered.
6. The duplicate report without the "dedicated seal for inspection and testing" of the institution is invalid.
7. Each page of the report is an integral part of the report. Our organization shall not be responsible for any misunderstanding or consequences arising from the improper use of the test report by the user.
8. Without the CMA seal, the report is invalid for social certification.

Test institute: Zhejiang Academy of Science and Technology for Inspection and Quarantine

Add: No. 398, Jianshe 3 Road, Xiaoshan District, Hangzhou, Zhejiang, China

Tel: +86 0571 8352 7187/185/193

Website: [www.zaiq.org.cn](http://www.zaiq.org.cn)